



पिंपरी चिंचवड महानगरपालिका, पिंपरी, पुणे-४११०१८ (8)

(नागरी व प्रशासकीय सेवेसाठी ISO ९००१-२००८ प्रमाणपत्र प्राप्त संस्था)

ड क्षेत्रिय कार्यालय, आरोग्य विभाग, रहाटणी-१७

दुरध्वनी क्र. : ९९२२५०१४५९/६०

E-mail : dward@pcmcindia.gov.in

Website : www.pcmcindia.gov.in

जावक क्र : डक्षे/७/कावि/३०४/२०१९

दिनांक: २९/११/२०१९



दाखला


दाखला देणेत येतो की, मे. अक्षरा इंटरनॅशनल स्कूल, सर्व्हे नं. १०९, अक्षरा लेन, प्रेरणा भवन समोर, वाकड, पुणे ४११०५७. या शाळेची तपासणी आरोग्य विभागामार्फत करणेत आली आहे. शाळेचे स्वच्छतागृह ड्रेनेज लाईनला जोडलेले आहे. सदर शाळेत सफाईकामी जंतुनाशकाचा वापर केला जातो. सदर शाळेत किटकनाशक फवारणीचे कामकाज केले जाते. शाळेची स्वच्छता समाधानकारक आहे. त्यामुळे सदर शाळेस त्यांचे दि. ०७/११/२०१९ चे मागणी अर्जानुसार आरोग्य विषयक ना हरकत दाखला दिल्याचे तारखेपासून १ वर्ष मुदतीकरता देणेत येत आहे.


क्षेत्रिय अधिकारी

पिंपरी चिंचवड महानगरपालिका

ड क्षेत्रिय कार्यालय, रहाटणी १७.

PRINCIPAL
Akshara International School
Wakad, Pune - 411057.





ANVIKSH

TESTING LABORATORY

Mobile
9623451032
8830762218

AN ISO 9001 : 2015

TESTING FOR WATER, FOOD & SOIL

Lab Add.: Dinkar Bungalow, Plot No. 7, Kharewadi, Near Pragati Vidyalaya, Behind Santosh Hall, Sinhagad Road, Pune - 411051

GSTIN 27AGDPJ8525A1ZP | Email : info@anvikshlabs.com, mahesh.joshi@anvikshlabs.com

Test Report

Name of Client	Akshara International School, Wakad, Pune-411057		
Sample Code	4640	Sample Collection Date	14/07/2023
Report Date	17/07/2023	Date of Analysis	14-17/07/2023
Sample details	Drinking Water	Sample Received	1000 ml
Report No.	ATL/MBCH/4640/23-24	Sample Collected By	Customer

Result Table

Sr. No	Parameters	Observed Values	Desirable Limits	Permissible Limits
Microbiological Test				
1	<i>E. coli</i>	Absent	Absent in 100 ml	Absent in 100 ml
2	<i>Coliforms</i>	Absent	Absent in 100 ml	Absent in 100 ml
3	Total Plate Count	48	500 cfu/ml	500 cfu/ml
Chemical Test				
1	pH	7.13	6.5-8.5	6.5-8.5
2	Total Dissolved Solids	160	500 mg/lit	2000 mg/lit
3	Alkalinity	18.75	200 mg/lit	600 mg/lit
4	Total Hardness	100.08	300 mg/lit	600 mg/lit
5	Chlorides	5.32	250 mg/lit	1000 mg/lit
6	Calcium	16.03	75 mg/lit	200 mg/lit
7	Magnesium	14.58	30 mg/lit	100 mg/lit
8	Turbidity	Nil	1 NTU	5 NTU

Abbreviation: cfu stands for colony forming unit.

Reference:

1) Testing Method: United States Environmental Protection Agency (EPA) Method 1604: Total Coliforms and *Escherichia coli* in Water by Membrane Filtration Using a Simultaneous Detection Technique

2) IS 1622:1987 Methods of Sampling and Microbiological Examination of Water.

3) IS 3025 (Part 11,16,13,21,32,40)

4) Limit as per IS 10500: 1993 Drinking Water Specifications

Remark: Result of collected Water Sample was Found to be within safety limit as prescribed by Drinking Water Specification IS 10500 for the tests conducted above

Prepared By,

-----End of Report-----

Authorized Signatory

Terms and Conditions

1. The above results pertain only to the sample tested.

2. Sample is retained by us only for 7 days from the date of receipt.

3. Test Report shall not be reproduced, except in full, without written permission of Anviksh Testing Laboratories.

4. Any correction to this report invalidates the report.

PRINCIPAL
Akshara International School
Wakad, Pune - 411057.

